

Advancing Microgrid Resilience Through Vehicle-to-Grid Integration: A Review of Current Trends and Future Directions

Khairul Bashar Akash^{1,*}, Shishir Ahmed², Md Afrad Hasan Emon³, Sk Md Raihan Shifat⁴

^{1,2} Department of Computer Science and Technology, Hubei University of Automotive Technology, Shiyan, China

³ Department of Electrical and Electronic Engineering, European University of Bangladesh, Dhaka, Bangladesh

⁴ Department of Computer Science and Technology, Southwest University of Science and Technology, Mianyang, China

Email: ¹ Khairulbasharakash@gmail.com, ² shishir.sh136318@gmail.com, ³ afrademon@gmail.com,

⁴ raihan.shifat01@gmail.com

*Corresponding Author

Abstract—The integration of vehicle-to-grid (V2G) technology within microgrids is emerging as a transformative solution to enhance the resilience, reliability, and efficiency of modern energy systems. With electric vehicle (EV) adoption accelerating worldwide, V2G allows EVs to function not only as transportation assets but also as mobile, bidirectional energy storage resources capable of strengthening grid flexibility. By enabling EVs to discharge electricity back into the grid, V2G systems contribute to critical grid services such as peak shaving, load leveling, frequency regulation, and emergency backup during power disruptions. For microgrids, which are decentralized energy systems designed to operate either independently or in coordination with the main grid, the integration of V2G significantly improves stability, demand management, and the capacity to supply critical loads under adverse conditions. This dual functionality positions V2G as an important enabler of resilient, community-based energy networks. Nevertheless, widespread deployment faces challenges, including concerns over battery degradation, the absence of standardized interoperability, high infrastructure and implementation costs, and regulatory and market uncertainties. Furthermore, the full potential of V2G relies heavily on advancements in communication protocols, optimization-based energy management strategies, and intelligent control algorithms that can balance user preferences with system needs. This review examines the present state of V2G integration in microgrids, outlining its advantages, barriers, and future research directions, while emphasizing the importance of supportive regulations, large-scale pilot projects, and continued technological innovation in enabling the transition toward decentralized, decarbonized, and digitized energy systems.

Keywords—Vehicle-to-Grid (V2G), Microgrids, Resilience, Electric Vehicles (EVs), Energy Storage, Peak Shaving, Frequency Regulation, Smart Grids, Renewable Energy, Energy Management Systems

I. INTRODUCTION

The global transition toward decarbonized, decentralized, and digitized energy systems has accelerated the development of microgrids [1]. These self-contained power networks are capable of operating either autonomously or in coordination with the main grid [2]. Despite their advantages, microgrids remain vulnerable to disruptions caused by natural disasters, cyber-attacks, and equipment failures [3]. Therefore, strengthening their resilience defined here as the capacity to anticipate, withstand, adapt to, and recover from

disturbances while continuing to supply critical loads is a crucial objective. This has become particularly urgent in light of increasing extreme weather events, widespread grid outages, and growing energy security concerns [4], especially in remote and disaster-prone regions. Particularly in distant or vulnerable places. However, intermittent renewable energy sources like wind and solar can provide a challenge to microgrid stability [5]. In this situation, energy storage becomes essential for maintaining a balance between supply and demand in the event of supply changes or system interruptions. Concurrently, the fast worldwide uptake of electric vehicles (EVs) offers a revolutionary chance to rethink mobile storage as a component of the energy system [6]. EV batteries and the electric grid or microgrid may exchange energy in both directions thanks to V2G technology [7].

EVs may now release stored electricity back into the grid, therefore serving as distributed energy storage devices. V2G systems greatly improve overall system resilience when combined with microgrids to provide load balancing, backup power delivery, peak shaving, and voltage stability [8], [9]. The combination of V2G with microgrids signifies a revolution in decentralized energy management. In North America, Europe, and Asia, a number of pilot studies and practical demonstrations have demonstrated the technical viability and possible advantages of V2G in microgrid applications [10].

A major challenge for microgrid resilience arises from the intermittency of renewable energy sources such as wind and solar. To mitigate these fluctuations, reliable energy storage systems are essential for balancing supply and demand during periods of variability or disruption. At the same time, the rapid global adoption of electric vehicles (EVs) presents a transformative opportunity: through V2G technology, EV batteries can exchange power bidirectionally with the grid or microgrid, functioning as mobile and flexible storage resources. As shown in Fig. 1, V2G facilitates energy sharing between renewable generators, the grid, and EVs, while Fig. 2 highlights the communication and control infrastructure required to coordinate this interaction effectively.

The integration of V2G technology into microgrids faces several challenges, including accelerated battery degradation, the absence of standardized communication protocols,

regulatory uncertainties, and concerns regarding vehicle availability and user participation [11].

This review aims to provide a comprehensive assessment of current trends in V2G-enabled microgrids, focusing on their potential to enhance system resilience. The technological architecture of V2G integration is examined, along with the main advantages and implementation challenges. In order to facilitate widespread adoption, it also exposes research gaps and highlights current case examples. This study provides strategic insights for academics, energy planners, and policymakers looking to use V2G technology to create smarter, more resilient energy networks by combining the body of current literature with real-world experiences.




Fig. 1. V2G integration with renewable and conventional energy sources [12]




Fig. 2. V2G communication and frequency regulation system [13]

II. FUNDAMENTALS OF V2G TECHNOLOGY

Modern power networks are undergoing a paradigm shift thanks to V2G technology, which turns electric vehicles (EVs) from passive loads into active energy resources that can support grid flexibility and stability [14]. Fundamentally, V2G makes it possible for EV batteries and the electrical grid to exchange energy in both directions, enabling the dispatch of stored energy during times of high demand or system disruptions [15]. By adding a dynamic storage component to distributed energy systems like microgrids, this feature not only increases the usefulness of EVs.

- **V2G System Architecture:** EVs with bidirectional inverters, intelligent charging infrastructure, energy management systems (EMS), and a grid communication interface are the main elements of a typical V2G system [16]. These parts work together to facilitate smooth charging and discharging procedures in response to market signals, emergency situations, or real-time grid circumstances. The system distributes electricity based on the requirements from each server. To enable this two-

way energy exchange, bidirectional charging stations Level 2 AC or DC fast chargers are necessary.

- **Communication and Control Protocols:** Strong communication and control systems are necessary for V2G functioning in order to manage grid interactions, coordinate power flow, and guarantee user preferences are honored [17]. Secure data interchange between EVs, chargers, and grid operators is made possible by international protocols like ISO/IEC 15118 and open charge point protocol (OCPP) [18], [19]. In order to optimize charging/discharging schedules in compliance with grid needs and user limits, advanced control strategies whether centralized, decentralized, or hierarchical are increasingly being merged with real-time data analytics and artificial intelligence.
- **Battery Technologies and Bidirectional Power Flow:** Battery chemistry and inverter design have a significant impact on the dependability and efficiency of V2G systems [20]. Modern EVs are mostly powered by lithium-ion batteries, which have advantageous features including a high energy density, quick charging, and a comparatively long cycle life [21]. However, the use of bidirectional energy flow creates problems regarding battery deterioration, cycle life decrease, and thermal stress. Therefore, to ensure technological and economic sustainability, current research focuses on creating battery-friendly dispatch mechanisms and optimizing charging algorithms.

III. MICROGRID ARCHITECTURE AND RESILIENCE CONCEPTS

A self-sufficient energy system that can function both independently and in connection with the main grid is known as a microgrid [22]. To provide dependable electricity, it integrates energy storage, backup generators, and renewable energy sources (wind, solar) [23]. By automatically isolating faults, preserving supplies during outages, and incorporating smart controls for efficiency, microgrids improve resilience. They minimize costs, promote sustainability, and lessen grid dependency while withstanding physical and cyber interruptions to provide uninterrupted energy access making them perfect for hospitals, rural locations, and disaster-prone areas.

A. Overview of Microgrid

A microgrid is a small-scale energy system that may work alone or in tandem with the national grid to produce, store, and distribute power [24]. It incorporates several sources, including solar photovoltaics, wind, biomass, and occasionally diesel generators [25]. It is frequently paired with sophisticated controllers and battery storage. In isolated or rural locations where expanding grid infrastructure is either financially or technically impractical, microgrids work particularly well [26]. Microgrids serve vital services like lighting, healthcare, education, and local enterprises by supplying dependable, decentralized electricity. In Fig. 3, shows a smart microgrid system that combines solar, wind, and storage. Microgrids employ centralized control systems that regulate the flow of information and energy among residential, commercial, and industrial sectors. Their modular architecture allows customization to align with the specific

energy needs and resource availability of individual communities. Operating in “island mode” during grid failures, microgrids enhance energy resilience by ensuring continuous supply to critical loads. Despite challenges such as high initial investment and maintenance costs, they deliver long-term benefits in terms of energy reliability, environmental sustainability, and socioeconomic development. With appropriate financial support and enabling policy frameworks, microgrids hold significant potential to transform rural electrification.




Fig. 3. Architecture of a smart microgrid integrating renewable energy sources and intelligent control [27]

B. Microgrid Operational Modes

Grid-connected and islanded are the two primary modes of operation for microgrids [28]. When the microgrid is in the grid-connected mode, it communicates with the main utility grid and exchanges electricity according to pricing, generation circumstances, and demand [29]. Services like peak shaving, energy trading, and demand response are supported in this mode. By controlling energy storage devices, distributed energy resources (DERs), and V2G-capable electric cars, the central controller maximizes power flows. On the other hand, the microgrid functions in islanded mode, which isolates it electrically from the main grid during scheduled outages or grid breakdowns [30]. In this mode, the system's stability and capacity to serve key loads are totally dependent on local energy sources. By regulating voltage and frequency and supplying backup power, V2G-enabled EVs improve islanded performance [31]. The microgrid's resistance to disruptions is increased by its smooth transition between different modes, which guarantees uninterrupted functioning. Safe and effective mode transitions need sophisticated control schemes and real-time coordination.

C. Concept of Resilience in Microgrid

The capacity of microgrids to anticipate, endure, respond to, and recover from unforeseen disruptions like natural catastrophes, cyberattacks, or grid failures is known as resilience [32]. Resilience places more emphasis on sustaining vital activities during disruptions and returning to full performance thereafter than traditional dependability, which aims to reduce the frequency and length of power outages. Adaptability (learning and improving after events), recovery (speed of system restoration), robustness (ability to withstand disruptions), and resourcefulness (efficient use of existing assets) are important aspects of resilience. During outages, a resilient microgrid may provide electricity to priority loads by utilizing local resources such as storage systems, renewable energy, and V2G-enabled electric cars [33]. The microgrid's capacity to withstand shocks and

continue operating is improved by the integration of flexible resources and sophisticated control systems. Resilience has emerged as a key design goal for contemporary microgrid systems, particularly in distant and critical infrastructure locations, as extreme weather events and grid vulnerabilities grow more frequent.

D. Enhancing Microgrid Resilience with V2G

V2G technology substantially enhances microgrid resilience by allowing EVs to operate as mobile, dispatchable energy storage assets [34]. During grid outages or disturbances, V2G-enabled EVs can provide backup power, maintain the continuity of critical loads, and contribute to voltage and frequency regulation. In islanded mode, these vehicles support energy balance and reduce dependence on stationary storage systems [35]. Moreover, V2G enables black start functionality by supplying the initial power necessary to restore microgrid operations following a complete shutdown. V2G also supports black start capabilities by providing initial power to restart the microgrid after a complete shutdown. When aggregated, EV fleets can function as a virtual power plant, offering scalable energy reserves that increase system redundancy and flexibility. Additionally, during grid-connected operation, V2G integration enhances demand-side responsiveness, load control, and peak shaving, which subtly increases the system's resilience to future disturbances. Microgrids can maximize grid support and battery health by scheduling charging and discharging activities appropriately by integrating real-time data with smart control systems. V2G is therefore essential to creating resilient and adaptable microgrid.

E. Standards and Communication Protocols

EVs may now be used as mobile energy storage assets that can assist grid operations during disturbances thanks to V2G technology, which is essential for enhancing microgrid resilience [36]. Due to crises or malfunctions, V2G-enabled EVs can release stored energy to power vital loads, maintain voltage and frequency, and lessen need on conventional backup systems when a microgrid is cut off from the main grid [37]. This is particularly useful in islanded mode, when system stability must be separately maintained by local generating and storage resources. By giving generating units the initial power, they need to restart following a complete shutdown, V2G also improves black start capabilities [38]. By enabling demand response, load balancing, and peak shaving in grid-connected mode, V2G helps to increase resilience by lessening the strain on the system during regular operations [39]. Fleets of electric vehicles (EVs) can function as a virtual power plant, providing dispersed, scalable, and adaptable energy assistance when managed by intelligent control systems and aggregators. All things considered, V2G greatly improves microgrids' resilience, recovery ability, and flexibility.

IV. ROLE OF V2G IN ENHANCING MICROGRID RESILIENCE

Mobile, intelligent, and dispatchable energy resources are introduced by V2G technology, which significantly improves microgrid resilience. Among V2G's most important contributions are load balancing and peak shaving [40]. In

order to maintain power balance and lower peak loads during times of high demand, V2G-enabled electric vehicles (EVs) can release energy back into the microgrid. In addition to reducing the need for costly and environmentally harmful peaking generators, this increases the microgrid's overall effectiveness and operational flexibility.

A. Peak Shaving and Load Balancing

V2G technology allows electric cars (EVs) to function as programmable energy storage units, which is essential for microgrid load balancing and peak shaving [41]. V2G-enabled EVs may release stored energy to the grid at times of peak demand, when the microgrid's load is at its maximum, lowering the peak load. As a result, there is less strain on generating assets and less need to turn on costly or carbon-intensive peaking units. V2G lowers operating expenses and promotes more reliable grid operation by flattening the demand curve [42]. During periods of low demand or surplus generation particularly from intermittent renewable sources EVs can absorb excess energy through smart charging. This bidirectional exchange supports supply demand balance within the microgrid while enhancing operational stability. Intelligent scheduling of charging and discharging, informed by time-of-use pricing, load forecasts, and user preferences, further increases the flexibility of load management. When coordinated at the fleet level, V2G-enabled EVs function as a distributed balancing resource, mitigating fluctuations and optimizing energy utilization. Collectively, these capabilities significantly enhance both the economic efficiency and operational performance of microgrids in real-time load management.

B. Islanded Operation Support

Microgrid functioning during islanded mode, when the system is cut off from the main utility grid, is greatly aided by V2G technology [43]. Because of the necessity to provide important loads and the limited generating resources, stability becomes difficult to sustain in such situations. When traditional sources are insufficient or unavailable, V2G-enabled electric cars (EVs) can discharge electricity to the microgrid, acting as portable and adaptable energy storage devices that aid in frequency and voltage stabilization [44]. Their capacity to react quickly enables them to improve the dependability of isolated operations by serving as a buffer against abrupt changes in demand or unpredictability in renewable generation.

Furthermore, EVs may be deployed out in response to priority load needs, guaranteeing uninterrupted power to vital services like communication infrastructure, hospitals, and emergency shelters. Fleets of electric vehicles provide scalable support, enhancing redundancy and operational flexibility when controlled by intelligent controllers or aggregators [45]. During grid disruptions, this capability of supplying a localized energy source minimizes downtime, improves power quality, and facilitates quicker recovery. Consequently, during islanded operation, V2G is essential for enhancing microgrid resilience.

C. Emergency Backup Power

In the event of unplanned outages or calamities, V2G technology provides microgrids with emergency backup power, which has several benefits [46]. Important

infrastructure, including hospitals, water treatment plants, communication hubs, and emergency shelters, must have electricity when natural disasters like hurricanes, earthquakes, or grid failures strike [47]. Electric vehicles (EVs) with V2G capability can serve as mobile backup generators by rapidly releasing stored energy to supply these critical loads. In contrast to traditional diesel generators, electric vehicles (EVs) emit no pollutants and may be deployed in a flexible manner according to the location and demand urgency. V2G systems are very useful for improving microgrid resilience because of their real-time response capabilities and capacity to supply electricity where it is needed. EVs may be planned and prioritized to support the most important services when linked with intelligent energy management systems, extending operation during extended outages. Furthermore, EV fleets can provide a sizable amount of energy to stabilize the microgrid when combined. Therefore, V2G offers a cleaner, more intelligent, and more flexible alternative to conventional backup systems for emergency energy assistance.

D. Renewable Integration

Microgrids may more easily include renewable energy sources, especially wind and solar electricity, which are erratic and intermittent by nature, thanks to V2G technology [48]. A major obstacle for microgrids fueled by renewable energy is keeping a steady balance between supply and demand, particularly when weather-related variations in energy output cause fluctuations. By collecting extra energy during times of strong renewable generation and releasing stored power when generation declines, V2G-enabled electric vehicles (EVs) can assist mitigate these swings [49]. Grid stability is increased and a more reliable power supply is guaranteed by this two-way energy exchange. Additionally, by facilitating voltage and frequency regulation both of which are frequently influenced by abrupt variations in solar output V2G improves the dependability of renewable integration. Fleets of EVs can function as a distributed buffer to supplement stationary storage systems when managed by intelligent energy management systems. Because of this adaptability, microgrids may use more renewable energy without sacrificing dependability. All things considered, V2G improves the operational resilience and sustainability of microgrids with renewable integration.

E. Frequency and Voltage Regulation

The capacity of V2G technology to offer frequency and voltage control, which are both critical for preserving system stability and power quality, improves microgrid resilience [50]. Unexpected variations in load or generation can cause frequency deviations and voltage fluctuations in microgrids, particularly those that are fueled by fluctuating renewable energy sources or operate in islanded mode. Electric vehicles (EVs) with V2G capabilities can operate as fast-response resources by rapidly injecting or absorbing electricity to rectify these imbalances in real time [51]. EVs may react to frequency variations in a matter of seconds thanks to sophisticated control algorithms and real-time communication with the microgrid's energy management system, therefore averting instability or cascade failures. In a similar manner, voltage support is accomplished by enhancing power quality at local nodes by modifying reactive

power via inverter-based management. A distributed network of stabilizing resources is produced by a fleet of EVs working together, which lessens the need for fixed assets or central control. Because of its timeliness, V2G is a useful tool for upholding grid standards and boosting microgrids' operational resilience.

V. CURRENT TRENDS AND CASE STUDIES

Significant developments in V2G technology in recent years have made it a game-changing solution for microgrids. The growing demand for more robust, adaptable energy systems and the rising popularity of electric vehicles (EVs) are the main forces behind these advancements. Current V2G integration research trends focus on using real-time communication technologies, artificial intelligence (AI), and sophisticated smart control algorithms to optimize V2G operations and enable vital grid support services like emergency backup, frequency regulation, and peak shaving [52]. Table I, provides an overview of key case studies and emerging trends in V2G integration within microgrids, highlighting regional implementations, key applications, challenges, and future advancements in the field.

Table 1. Summary of current trends and case studies in V2G integration

Region	Case Study	Key Focus/Applications	Challenges	Emerging Trends
Japan	CHAdEMO Protocol Demonstrations	- Frequency regulation - Load balancing in islanded microgrids	- Battery degradation - Limited scalability in early trials	- Smart control systems for better grid integration
Europe	V2G Virtual Power Plants (VPPs)	- Aggregation of EV fleets - Ancillary services for grid stability	- Interoperability between EVs, chargers, and grid systems	- Blockchain-enabled energy transactions for V2G
United States	California Community Microgrids	- Emergency power supply - Demand response	- User acceptance - Regulatory barriers	- Vehicle aggregation for improved energy management
Global Trends	Integration with Renewable Energy	- Balancing renewable generation and consumption	- Need for improved energy storage solutions	- AI and machine learning for optimized V2G operations

Several pilot projects worldwide are demonstrating both the potential benefits and challenges of V2G-enabled microgrids. Notable case studies include:

- **Japan:** Early V2G demonstrations have been made possible in large part by the CHAdEMO protocol, especially in islanded microgrids where V2G systems have been effectively applied for load balancing and frequency control [53]. The capacity of EVs to offer grid stability in off-grid situations has been demonstrated by these experiments.
- **Europe:** Virtual power plants (VPPs) have been created by combining fleets of electric vehicles in extensive testing conducted around Europe [54]. By offering ancillary services like reactive power support and voltage regulation, these VPPs help to stabilize the grid and make it easier to integrate renewable energy sources.
- **United States:** V2G integration has been investigated in California for demand response and emergency power supply in community microgrids [55]. Especially in

situations involving vital infrastructure, these programs seek to improve energy dependability and guarantee power supply during grid outages.

VI. CHALLENGES AND FUTURE WORK

Although V2G integration is increasingly recognized as a means to enhance microgrid resilience, its large-scale adoption remains limited by technological, financial, and regulatory barriers [56]. A key challenge is battery degradation, as frequent charging and discharging can reduce the lifespan of EV batteries and discourage user participation. The absence of standardized communication protocols and limited interoperability across EV models and charging infrastructure further complicate integration. High capital costs for bidirectional chargers and necessary grid upgrades also pose significant obstacles, particularly in developing regions. From a regulatory perspective, unclear policies, insufficient legal frameworks for energy transactions, and a lack of financial incentives hinder broader engagement from both utilities and consumers. Furthermore, system dependability is also threatened by cybersecurity vulnerabilities related to bidirectional communication between EVs and the grid. Last but not least, issues with battery deterioration, vehicle availability, and inadequate financial returns continue to hinder user adoption. Unlocking V2G's full potential in resilient energy systems of the future requires addressing these issues.

- In V2G systems, frequent cycles of charging and discharging might hasten the wear of EV batteries, lower their lifespan and deter user engagement because of the possible long-term replacement costs.
- Large-scale V2G adoption is made more difficult by the lack of hardware standards and universal communication protocols, which restrict compatibility across various EVs, chargers, and grid systems.
- The upfront cost of bidirectional chargers, smart controllers, and necessary grid upgrades creates financial barriers, especially for small-scale or community-based microgrid projects.
- Many regions lack clear policies, market structures, and legal frameworks to support V2G services, making it difficult for utilities and consumers to engage confidently.
- Two-way data exchange between EVs and the grid introduces vulnerabilities, including potential threats from hacking, data breaches,

Future research in V2G integrated microgrids should focus on addressing current limitations while enhancing performance, scalability, and user engagement. One critical direction is the development of battery-friendly energy management algorithms that minimize degradation while maximizing grid support. Additionally, efforts are needed to create unified communication standards and protocols to ensure seamless interoperability among EVs, chargers, and grid operators. Artificial Intelligence (AI) and machine learning can play a major role in predictive scheduling, demand forecasting, and real-time decision-making for optimal V2G operation. Further investigation into blockchain-based energy trading platforms could enable secure, transparent, and decentralized V2G transactions. Pilot projects should also expand across diverse geographic and

socioeconomic contexts to test feasibility, particularly in rural and disaster-prone areas.

- Develop smart control strategies that reduce battery degradation while maintaining effective V2G performance for long-term EV user satisfaction.
- To guarantee interoperability and seamless integration among diverse EVs, chargers, and microgrid systems, establish standardized protocols and standards.
- Use artificial intelligence in microgrids to achieve real-time V2G control, optimal EV scheduling, and precise load forecasting.
- Explore blockchain technologies for secure, transparent, and decentralized V2G energy trading and transaction management.
- In order to verify scalability and practical V2G microgrid applications, extend pilot projects to rural, isolated, and disaster-prone regions.

VII. CONCLUSION

The integration of V2G technology into microgrids represents a transformative pathway toward more resilient, flexible, and sustainable energy systems. By enabling electric vehicles (EVs) to serve as mobile, bidirectional energy storage resources, V2G can support essential functions such as peak shaving, load balancing, frequency regulation, and emergency backup. Evidence from pilot projects worldwide confirms its potential to enhance energy independence and system stability, particularly during crises or grid disruptions. Despite these benefits, several challenges continue to hinder large-scale deployment. Battery degradation, interoperability limitations, high infrastructure costs, and regulatory uncertainty pose barriers not only to scalability but also to user participation and economic viability. Moreover, trade-offs such as preserving battery health versus maximizing grid support require careful consideration to ensure long-term acceptance and performance.

Future research and policy efforts should prioritize three areas. First, the development of standardized communication protocols and supportive regulatory frameworks is essential to ensure interoperability and market confidence. Second, pilot projects should expand to diverse contexts including rural, remote, and disaster-prone regions to evaluate scalability and socio-technical impacts. Third, advanced digital tools such as AI, machine learning, and blockchain offer promising opportunities for optimization and secure energy trading, but their application must be grounded in empirical validation. Overall, V2G-enabled microgrids hold significant promise for advancing decentralized and decarbonized energy systems. Unlocking this potential will require coordinated progress in technology, policy, and user engagement, supported by continued innovation and real-world demonstration.

REFERENCES

- [1] W. Ajaz and D. Bernell, "Microgrids and the transition toward decentralized energy systems in the United States: A Multi-Level Perspective," *Energy Policy*, vol. 149, p. 112094, 2021, <https://doi.org/10.1016/j.enpol.2020.112094>.
- [2] T. Saha, A. Haque, M. A. Halim, and M. M. Hossain, "A Review on Energy Management of Community Microgrid with the use of Adaptable Renewable Energy Sources," *International Journal of Robotics and Control Systems*, vol. 3, no. 4, pp. 824-838, 2023, <https://doi.org/10.31763/ijrcs.v3i4.1009>.
- [3] D. K. Mishra, P. K. Ray, L. Li, J. Zhang, M. J. Hossain, and A. Mohanty, "Resilient Control Based Frequency Regulation Scheme of Isolated Microgrids Considering Cyber Attack and Parameter Uncertainties," *Applied Energy*, vol. 306, p. 118054, 2022, <https://doi.org/10.1016/j.apenergy.2021.118054>.
- [4] A. Mohanty *et al.*, "Power system resilience and strategies for a sustainable infrastructure: A review," *Alexandria Engineering Journal*, vol. 105, pp. 261-279, 2024, <https://doi.org/10.1016/j.aej.2024.06.092>.
- [5] E. Khatun, M. M. Hossain, M. S. Ali, and M. A. Halim, "A Review on Microgrids for Remote Areas Electrification-Technical and Economical Perspective," *International Journal of Robotics and Control Systems*, vol. 3, no. 4, pp. 627-642, 2023, <https://doi.org/10.31763/ijrcs.v3i4.985>.
- [6] M. Khan, "Innovations in Battery Technology: Enabling the Revolution in Electric Vehicles and Energy Storage," *British Journal of Multidisciplinary and Advanced Studies*, vol. 5, no. 1, pp. 23-41, 2024, <https://doi.org/10.37745/bjmas.2022.0414>.
- [7] M. R. H. Mojumder, F. A. Antara, M. Hasanuzzaman, B. Alamri, and M. Alsharif, "Electric Vehicle-to-Grid (V2G) Technologies: Impact on the Power Grid and Battery," *Sustainability*, vol. 14, no. 21, p. 13856, 2022, <https://doi.org/10.3390/su142113856>.
- [8] S. Pang, C. Liu, C. Zhang, J. Zhang, and H. Zhang, "Leveraging Electric Vehicles for Enhancing Power System Resilience: A Review of Strategies and Challenges," *Current Sustainable/Renewable Energy Reports*, vol. 12, no. 1, pp. 1-8, 2025, <https://doi.org/10.1007/s40518-025-00259-8>.
- [9] M. Mahmoud and N. Shouman, "Vehicle-to-Grid and Grid-to-Vehicle Scheduling Based on Load Leveling and Peak Shaving," in *2024 6th International Conference on Smart Power & Internet Energy Systems (SPIES)*, pp. 218-223, 2024, <https://doi.org/10.1109/SPIES63782.2024.10982869>.
- [10] M. R. H. Mojumder, F. A. Antara, M. Hasanuzzaman, B. Alamri, and M. Alsharif, "Electric Vehicle-to-Grid (V2G) Technologies: Impact on the Power Grid and Battery," *Sustainability*, vol. 14, no. 21, p. 13856, 2022, <https://doi.org/10.3390/su142113856>.
- [11] S. Satheesh Kumar, B. Ashok Kumar, and S. Senthilrani, "Review of electric vehicle (EV) charging using renewable solar photovoltaic (PV) nano grid," *Energy and Environment*, vol. 35, no. 2, pp. 1089-1117, 2024, <https://doi.org/10.1177/0958305X231199151>.
- [12] R. Shi, S. Peng, T. Chang, and K. Y. Lee, "Annotated Survey on the Research Progress within Vehicle-to-Grid Techniques Based on CiteSpace Statistical Result," *World Electric Vehicle Journal*, vol. 14, no. 11, p. 303, 2023, <https://doi.org/10.3390/wevj14110303>.
- [13] H. Asano, H. Ishii, and H. Takano, "Distributed Energy Resource Integration for Carbon Neutral Power Systems: Market-Based Approaches to Ancillary Services and Microgrid Operation," *IEEE Transactions on Electrical and Electronic Engineering*, vol. 19, no. 5, pp. 598-607, 2024, <https://doi.org/10.1002/tee.24073>.
- [14] M. R. H. Mojumder, F. Ahmed Antara, M. Hasanuzzaman, B. Alamri, and M. Alsharif, "Electric Vehicle-to-Grid (V2G) Technologies: Impact on the Power Grid and Battery," *Sustainability*, vol. 14, no. 21, p. 13856, 2022, <https://doi.org/10.3390/su142113856>.
- [15] M. İnci, M. M. Savrun, and Ö. Çelik, "Integrating electric vehicles as virtual power plants: A comprehensive review on vehicle-to-grid (V2G) concepts, interface topologies, marketing and future prospects," *Journal of Energy Storage*, vol. 55, p. 105579, 2022, <https://doi.org/10.1016/j.est.2022.105579>.
- [16] M. Lukianov, I. Verbitsky, E. R. Cadaval, and R. Strzelecki, "An overview of bidirectional EV chargers: Empowering traction grid-powered chargers," *Studies in Systems, Decision and Control*, vol. 512, pp. 191-230, 2024, https://doi.org/10.1007/978-3-031-44772-3_9.
- [17] M. A. Hannan *et al.*, "Vehicle to grid connected technologies and charging strategies: Operation, control, issues and recommendations," *Journal of Cleaner Production*, vol. 339, p. 130587, 2022, <https://doi.org/10.1016/j.jclepro.2022.130587>.
- [18] S. Gupta, T. Varshney, P. Saini, and M. M. Hussain, "Standards and protocols for interoperability in smart EV systems," *Modern Computing Technologies for EV Efficiency and Sustainable Energy Integration*, pp. 115-150, 2025, <https://doi.org/10.4018/979-8-3373-2382-4.ch005>.
- [19] M. Helmy, M. T. Samy, and K. A. Azab, "Enhancing Cybersecurity Strategies for ISO15118 V2G Protocols within AUTOSAR-Based

- Systems,” *2024 International Conference on Computer and Applications, ICCA 2024*, pp. 1–6, 2024, <https://doi.org/10.1109/ICCA62237.2024.10927801>.
- [20] M. R. H. Mojumder, F. Ahmed Antara, M. Hasanuzzaman, B. Alamri, and M. Alsharaf, “Electric Vehicle-to-Grid (V2G) Technologies: Impact on the Power Grid and Battery,” *Sustainability*, vol. 14, no. 21, p. 13856, 2022, <https://doi.org/10.3390/su142113856>.
- [21] M. Al-saadi, J. Olmos, A. Saez-de-ibarra, J. Van Mierlo, and M. Bercibar, “Fast Charging Impact on the Lithium-Ion Batteries’ Lifetime and Cost-Effective Battery Sizing in Heavy-Duty Electric Vehicles Applications,” *Energies*, vol. 15, no. 4, p. 1278, 2022, <https://doi.org/10.3390/en15041278>.
- [22] M. A. Halim, M. M. Hossain, and M. J. Nahar, “Development of a Nonlinear Harvesting Mechanism from Wide Band Vibrations,” *International Journal of Robotics and Control Systems*, vol. 2, no. 3, pp. 467–476, 2022, <https://doi.org/10.31763/ijrcs.v2i3.524>.
- [23] M. Y. Worku, “Recent Advances in Energy Storage Systems for Renewable Source Grid Integration: A Comprehensive Review,” *Sustainability*, vol. 14, no. 10, p. 5985, 2022, <https://doi.org/10.3390/su14105985>.
- [24] Y. Chowdhuri, E. Khatun, M. Hossain, A. Halim, M. Y. Chowdhuri, and M. M. Hossain, “Current Challenges and Future Prospects of Renewable Energy: A Case Study in Bangladesh,” *International Journal of Innovative Science and Research Technology*, vol. 8, no. 4, pp. 576–582, 2023, <https://doi.org/10.5281/zenodo.7866172>.
- [25] J. Lata-García, N. Zamora Cedeño, G. Ampuño, F. Jurado, M. L. Swarupa, and W. Maliza, “Optimization and Evaluation of a Stand-Alone Hybrid System Consisting of Solar Panels, Biomass, Diesel Generator, and Battery Bank for Rural Communities,” *Sustainability (Switzerland)*, vol. 16, no. 20, p. 9012, 2024, <https://doi.org/10.3390/su16209012>.
- [26] J. T. Nuru, J. L. Rhoades, and J. S. Gruber, “The socio-technical barriers and strategies for overcoming the barriers to deploying solar mini-grids in rural islands: Evidence from Ghana,” *Technology in Society*, vol. 65, p. 101586, 2021, <https://doi.org/10.1016/j.techsoc.2021.101586>.
- [27] G. Henri, T. Levent, A. Halev, R. Alami, and P. Cordier, “pymgrid: An Open-Source Python Microgrid Simulator for Applied Artificial Intelligence Research,” *arXiv*, 2020, <http://arxiv.org/abs/2011.08004>.
- [28] S. Chandak and P. K. Rout, “Seamless transition of microgrid between islanded and grid-connected mode of operation,” *IET Energy Systems Integration*, vol. 3, no. 1, pp. 60–72, 2021, <https://doi.org/10.1049/esi2.12004>.
- [29] M. A. Halim, M. M. Hossain, M. S. Islam, and E. Khatun, “A Review on Techniques and Challenges of Energy Harvesting from Ambient Sources,” *International Journal of Scientific & Engineering Research*, vol. 13, no. 08, pp. 1254–1263, 2022, <https://doi.org/10.14299/ijser.2022.08.07>.
- [30] M. F. Ishraque, A. Rahman, S. A. Shezan, and S. M. Mueyeen, “Grid Connected Microgrid Optimization and Control for a Coastal Island in the Indian Ocean,” *Sustainability*, vol. 14, no. 24, p. 16697, 2022, <https://doi.org/10.3390/su142416697>.
- [31] K. B. Akash, M. Sumi Akter, A. H. Emon, M. M. Kazmi, and A. M. Islam, “Energy Management Strategies for Electric Vehicle Charging in Microgrids: A Case Study of Optimization Techniques,” *Control Systems and Optimization Letters*, vol. 3, no. 2, p. 2025, 2025, <https://doi.org/10.59247/csol.v3i2.202>.
- [32] S. Mishra, K. Anderson, B. Miller, K. Boyer, and A. Warren, “Microgrid resilience: A holistic approach for assessing threats, identifying vulnerabilities, and designing corresponding mitigation strategies,” *Applied Energy*, vol. 264, p. 114726, 2020, <https://doi.org/10.1016/j.apenergy.2020.114726>.
- [33] G. Kostenko and A. Zaporozhets, “Enhancing of the power system resilience through the application of micro power systems (microgrid) with renewable distributed generation,” *System Research in Energy*, vol. 2023, no. 3, pp. 25–38, 2023, <https://doi.org/10.15407/srenergy2023.03.025>.
- [34] B. Engineering, “The Influence of Electric Vehicle Availability on Vehicle-to-Grid Provision within a Microgrid,” *University of Sheffield*, 2023, <https://etheses.whiterose.ac.uk/id/eprint/33711>.
- [35] A. K. M. A. Habib, M. K. Hasan, M. Mahmud, S. M. A. Motakabber, M. I. Ibrahimya, and S. Islam, “A review: Energy storage system and balancing circuits for electric vehicle application,” *IET Power Electronics*, vol. 14, no. 1, pp. 1–13, 2021, <https://doi.org/10.1049/pel2.12013>.
- [36] J. Dugan, S. Mohagheghi, and B. Kroposki, “Application of mobile energy storage for enhancing power grid resilience: a review,” *Energies*, vol. 14, no. 20, p. 6476, 2021, <https://doi.org/10.3390/en14206476>.
- [37] M. R. H. Mojumder, F. Ahmed Antara, M. Hasanuzzaman, B. Alamri, and M. Alsharaf, “Electric Vehicle-to-Grid (V2G) Technologies: Impact on the Power Grid and Battery,” *Sustainability*, vol. 14, no. 21, p. 13856, 2022, <https://doi.org/10.3390/su142113856>.
- [38] D. Aguilar-Dominguez, J. Ejeh, S. F. Brown, and A. D. F. Dunbar, “Exploring the possibility to provide black start services by using vehicle-to-grid,” *Energy Reports*, vol. 8, pp. 74–82, 2022, <https://doi.org/10.1016/j.egy.2022.06.111>.
- [39] M. A. Rahman, “Optimizing Smart Grid Flexibility and Resilience with Demand Response, Renewable Integration and Energy Storage,” *Optimizing Smart Grid Flexibility and Resilience with Demand Response, Renewable Integration and Energy Storage*, 2025, <https://urn.fi/URN:NBN:fi-fe2025051545847>.
- [40] M. M. Rana, M. Atef, M. R. Sarkar, M. Uddin, and G. M. Shafiullah, “A Review on Peak Load Shaving in Microgrid-Potential Benefits, Challenges, and Future Trend,” *Energies*, vol. 15, no. 6, p. 2278, 2022, <https://doi.org/10.3390/en15062278>.
- [41] O. Ouramdane, E. Elbouchikhi, Y. Amirat, and E. S. Gooya, “Optimal sizing and energy management of microgrids with Vehicle-to-Grid technology: A critical review and future trends,” *Energies*, vol. 14, no. 14, p. 4166, 2021, <https://doi.org/10.3390/en14144166>.
- [42] X. Lei, H. Yu, J. Zhong, Y. Jia, Z. Shao, and L. Jian, “Exploring electric vehicle’s potential as capacity reservation through V2G operation to compensate load deviation in distribution systems,” *Journal of Cleaner Production*, vol. 451, p. 141997, 2024, <https://doi.org/10.1016/j.jclepro.2024.141997>.
- [43] O. Ouramdane, E. Elbouchikhi, Y. Amirat, and E. S. Gooya, “Optimal sizing and energy management of microgrids with Vehicle-to-Grid technology: A critical review and future trends,” *Energies*, vol. 14, no. 14, p. 4166, 2021, <https://doi.org/10.3390/en14144166>.
- [44] M. R. H. Mojumder, F. Ahmed Antara, M. Hasanuzzaman, B. Alamri, and M. Alsharaf, “Electric Vehicle-to-Grid (V2G) Technologies: Impact on the Power Grid and Battery,” *Sustainability*, vol. 14, no. 21, p. 13856, 2022, <https://doi.org/10.3390/su142113856>.
- [45] V. Nikam and V. Kalkhambkar, “A review on control strategies for microgrids with distributed energy resources, energy storage systems, and electric vehicles,” *International Transactions on Electrical Energy Systems*, vol. 31, no. 1, p. e12607, 2021, <https://doi.org/10.1002/2050-7038.12607>.
- [46] S. Hossain *et al.*, “Grid-Vehicle-Grid (G2V2G) Efficient Power Transmission: An Overview of Concept, Operations, Benefits, Concerns, and Future Challenges,” *Sustainability*, vol. 15, no. 7, p. 5782, 2023, <https://doi.org/10.3390/su15075782>.
- [47] M. H. Babaei and S. D. Wong, “Electric vehicles in emergencies and evacuations: a review of resilience and future research directions,” *Transportation Letters*, vol. 17, no. 6, pp. 1101–1113, 2025, <https://doi.org/10.1080/19427867.2024.2415753>.
- [48] S. Shahzad, M. A. Abbasi, H. Ali, M. Iqbal, R. Munir, and H. Kilic, “Possibilities, Challenges, and Future Opportunities of Microgrids: A Review,” *Sustainability*, vol. 15, no. 8, p. 6366, 2023, <https://doi.org/10.3390/su15086366>.
- [49] M. Ntombela, K. Musasa, and K. Moloi, “A Comprehensive Review of the Incorporation of Electric Vehicles and Renewable Energy Distributed Generation Regarding Smart Grids,” *World Electric Vehicle Journal*, vol. 14, no. 7, 2023, <https://doi.org/10.3390/wevj14070176>.
- [50] M. Wan, H. Yu, Y. Huo, K. Yu, Q. Jiang, and G. Geng, “Feasibility and Challenges for Vehicle-to-Grid in Electricity Market: A Review,” *Energies*, vol. 17, no. 3, p. 679, 2024, <https://doi.org/10.3390/en17030679>.
- [51] A. Q. Al-Shetwi, M. A. Hannan, H. M. K. Al-Masri, and M. Z. Sujod, “Latest advancements in smart grid technologies and their transformative role in shaping the power systems of tomorrow: an overview,” *Progress in Energy*, vol. 7, no. 1, 2025, <https://doi.org/10.1088/2516-1083/ada198>.
- [52] F. Ahmed, A. Uzzaman, M. I. Adam, M. Islam, M. M. Rahman, and A. M. Islam, “AI-Driven Microgrid Solutions for Enhancing Energy

- Access and Reliability in Rural and Remote Areas: A Comprehensive Review,” *Control Systems and Optimization Letters*, vol. 3, no. 1, pp. 110–116, 2025, <https://doi.org/10.59247/csol.v3i1.183>.
- [53] A. Zecchino, A. Thingvad, P. B. Andersen, and M. Marinelli, “Test and modelling of commercial V2G CHAdeMO chargers to assess the suitability for grid services,” *World Electric Vehicle Journal*, vol. 10, no. 2, p. 21, 2019, <https://doi.org/10.3390/wevj10020021>.
- [54] F. Bruncrona, “Building virtual power plant capabilities within large energy companies: a case study in the Nordics,” *Universitat Politècnica de Catalunya*, 2024, <https://upcommons.upc.edu/entities/publication/d2d00025-d3fb-4f10-8310-fcbbaf0e4157>.
- [55] J. Lee, G. Razeghi, and S. Samuelsen, “Utilization of Battery Electric Buses for the Resiliency of Islanded Microgrids,” *Applied Energy*, vol. 347, p. 121295, 2023, <https://doi.org/10.1016/j.apenergy.2023.121295>.
- [56] A. Uzzaman, M. I. Adam, S. Alam, and P. Basak, “Review on the Safety and Sustainability of Autonomous Vehicles: Challenges and Future Directions,” *Control Systems and Optimization Letters*, vol. 3, no. 1, pp. 103–109, 2025, <https://doi.org/10.59247/csol.v3i1.185>.